

# 16. Administration during active alarms



During active alarms, administration is only available with a few restrictions.



To be able to access the administration, you must have the **Administrator** user role or you must have been granted the appropriate **access rights**.

The restrictions relate to editing and deleting alarm types, alarm levels, additional information, participation options, automatic alarm escalations, the building structure, plans and route maps.

Editing and deleting is also possible for everything else.

The creation of new elements is possible without restrictions.



You should therefore be very careful when creating new elements, as it may be the case that you will not be able to edit them at first if there is an active alarm.

WORKFLOWS

WORKFLOWS

LOCATION MANAGEMENT

LOGS

Administration

Logout

At least one alarm is currently active. Therefore you have only limited access to the administration system. Please end all active alarms in the Cockpit first in order to fully reactivate the administration. You may not be authorized for active alarms and cannot see them. Please contact your administrator for this.

Go to Cockpit

1 ALARM

TRIGGER

ACTIONS

Alarm types

Alarm schedules

Autom. Alarm escalations

Workflows

Task lists

Contact lists

Alarm devices